

## B133 Facility Screening Report (SCR)

G.A. Cooper

February 7, 2007

## **Disclaimer**

This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor the University of California nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or the University of California, and shall not be used for advertising or product endorsement purposes.

This work was performed under the auspices of the U.S. Department of Energy by University of California, Lawrence Livermore National Laboratory under Contract W-7405-Eng-48.

LLNL Facility Screening Report (SCR) for B133					
	Facility Name				
Lead Preparer: Ronneil Estrellado Date	Performed: 5/3/06				
Facility Description					
B133 is located in the southwest quadrant inside the 1 square mile site of Lawrence Livermore National Laboratory. The property is about 250 meters from the nearest boundary along Vasco Road. Building 133 is a 1 story steel framed building constructed in 1994 with stainless steel sidings. The facility covers 5,631 gross square feet of space. The building is used to house equipment to heat and cool buildings 132N and 132S. A 1380 volts electrical substation is located outside on the northeast corner, along with 2 diesel generators and a 1000 gallons diesel fuel tank. An evaporative cooling tower is located to the south of B133 to dissipate heat from the chillers located in B133. The inside of the facility is divided into three main rooms housing the cooling system units, the boilers, and the electrical distribution panels. The facility has automatic sprinkler system installed through out and a Freon alarm located in room 1000.					
Define facility type:	Owner Organization:				
Check:  ☐ Single Structure or Area: (B/Tr/A) B133 ☐ Complex of Buildings: Designation ☐ Segment* of Bldg or Complex: Seg.# *Attach justification for segmentation	Directorate: Chemistry, Materials, and Life Sciences Facility AD: Tomas Diaz de la Rubia				
Final Facility Classification: (Check)					
□ LSI □ Low □ Moderate □ High □ N	uclear Facility Accelerator				
Concurrence Signatures for Facility Classified as LSI**:  Lead Preparer:  Date: 1/23/07  AB Section Leader or designee: M. Van Wanneldon Date: 1/24/07  ES&H Team Leader or designee: Willy A. Aug. Date: 1/24/07					
Approval Signature for Facility Classified as LSI*	*:				
Facility Management: // ACOY7	Date: 1/26/07				
Supporting Documentation Appended Con	iments:				
Check as appropriate:  Justification for Segmentation  Chemical Hazard List  Radiological Hazard List  Explosive Hazard List  Building Layout  ** Signatures are not required on this form for facilities classified as Low, Moderate or High. Approval signatures for these are on the cover of the Tier 2 or Tier 3 SBDs.					

LLNL Facility Screening Report (SCR) for B133 Facility Name				
Lead Preparer: Ronneil Estrellado	Date Performed: 5/3/06			
Facility Description				
B133 is located in the southwest quadrant inside the 1 square mile site of Lawrence Livermore National Laboratory. The property is about 250 meters from the nearest boundary along Vasco Road. Building 133 is a 1 story steel framed building constructed in 1994 with stainless steel sidings. The facility covers 5,631 gross square feet of space. The building is used to house equipment to heat and cool buildings 132N and 132S. A 1380 volts electrical substation is located outside on the northeast corner, along with 2 diesel generators and a 1000 gallons diesel fuel tank. An evaporative cooling tower is located to the south of B133 to dissipate heat from the chillers located in B133. The inside of the facility is divided into three main rooms housing the cooling system units, the boilers, and the electrical distribution panels. The facility has automatic sprinkler system installed through out and a Freon alarm located in room 1000.				
Define facility type:	Owner Organization:			
Check:  Single Structure or Area: (B/Tr/A) B133  Complex of Buildings: Designation  Segment* of Bldg or Complex:  Seg.#  Seg.#	Directorate: Chemistry, Materials, and Life Sciences Facility AD: Tomas Diaz de la Rubia			
*Attach justification for segmentation				
Final Facility Classification: (Check)	☐ Nuclear Facility ☐ Accelerator			
Concurrence Signatures for Facility Classifie	ed as LSI**:			
Lead Preparer :	Date:			
AB Section Leader or designee:	Date:			
ES&H Team Leader or designee:				
Approval Signature for Facility Classified as				
Facility Management:	Date:			
Supporting Documentation Appended	Comments:			
Check as appropriate:  Justification for Segmentation  Chemical Hazard List  Radiological Hazard List  Explosive Hazard List  Building Layout  ** Signatures are not required on this form for facilities classified as Low, Moderate or High. Approval signatures for these are on the cover of the Tier 2 or				

Identification of Operations, Inventories, and Hazards						
List key operatio	ns that are	conducted within the facil	ity:			
List key operations that are conducted within the facility:  Building 133 is used to supply electrical power, chilled water, and hot water to Bldgs 132 N & S. Primary activities include servicing and maintaining chillers, boilers, and electrical distribution equipment.						
Did Facility Management receive any notifications of credible external threats from nearby facilities?						
If wes list the fol	lowing for	each notification:				
If yes, list the following for ea Source Facility:		Facility Contact(s):	Phone # (s):			
Describe Hazard(s): N/A						
Hazard Identification Table						
Check the hazard t	ypes found ir	the facility.				
Not Found	Found					
$\boxtimes$		Biological Hazards	Complete block I, below			
	$\boxtimes$	Chemical Hazards	Complete block II, below			
$\boxtimes$		Explosive Hazards	Complete block III, below			
$\boxtimes$		Radiological Hazards	Complete block IV, below			
	$\boxtimes$	Industrial Hazards	Complete block V, below			

I. Biological Hazards	II. Chemical Hazards		
Check BioHazard Type	Check ChemHazard Type		
☐ Non-Select Agents	☐ Flammable, volatile or fuming		
Check highest group in facility:	Toxic materials (acutely toxic, toxic, systemic		
RG1 Agents	toxin, toxic gases)		
RG2 Agents	Corrosives/irritants		
RG3 Agents	Reactive materials (e.g., air/water sensitive;		
Select Agents	pyrophoric; thermally, shock, or friction		
Select highest group in facility:	sensitive; perchlorate)  Carcinogens, mutagens, reproductive hazards		
RG1 Agents	Pesticides		
RG2 Agents	Beryllium		
RG3 Agents	Materials of special concern (e.g., alkali metals,		
Other Die Henerde (e. e. Dleed enveleie eeid leb	fluorine, asbestos, lead, mercury, PCB)		
Other BioHazards (e.g., Blood, nucleic acid, lab animals, contaminated needles/sharps,	Other regulated metals (e.g., chromium, copper,		
animals, contaminated needles/sharps, animal/human tissues)	nickel, zinc)		
,	Other: Freon 134		
Biological Safety Level (BSL)	Do any chemicals exceed LSI classification?		
Check highest level in facility:	□ YES □ NO		
$\square$ N/A $\square$ BSL-1 $\square$ BSL-2 $\square$ BSL-3	<u> </u>		
	For chemicals that exceed LSI classification, attach maximally planned chemical inventory listing.		
III. Explosive Hazards	IV. Radiological Hazards		
Check	Check Sum of Ratio		
Primary High Explosives	Sum of Ratio 1 of RQ thresholds (40 CFR 302.4 Appendix B)		
Secondary High Explosives	>1 of RQ thresholds (40 CFR 302.4 Appendix B)		
Propellants/Low Explosives	STD-1027-92, Table A.1)		
Firearms Ammunition	Cat. 3 Thresholds (DOE-STD-1027-92,		
Do any of the explosive types checked above have	Table A.1) < Cat. 2 Thresholds (DOE-STD-1027-		
any of the following associated hazards?	92, Table A.1)		
Fragmentation Hazards (Primary Fragments)	Does facility contain the following?		
Group L Explosives	Radiation Generating Devices:		
Attach maximally planned inventory listing for each	Radiation generating devices not covered by		
explosive type checked.	DOE O 420.2A (e.g., X-rays, Electron Beams,		
	Radiography Equipment): class		
	Radiation generating devices covered by DOE O 420.2A (Accelerators).		
	Exempted materials:		
	Radioactive Certified Sealed Sources		
	Rad. In Type B Containers with current		
	certificates of compliance		
	Either in quantities>Cat. 3 thresholds (DOE-		
	STD-1027-92, Table A.1)		
	Attach listing of maximally planned radiological materials inventory.		
	·		

V. Industrial Hazards				
Check if hazard present	Industrial Hazard		l hazard(s) for each general dustrial Hazards found.)	List industrial hazard(s) that could directly impact the public (fence-line) or colocated worker (100 m).
	Electrical	□ Battery banks, ☒ Cable runs, ☒ Diesel generators, ☒ Electrical equipment, □ Heaters, ☒ High voltage (> 600V), □ Motors, ☒ Power tools, ☒ Pumps, □ Service outlets, ☒ Fittings, ☒ Switchgear, ☒ Transformers, ☒ Capacitors, □ Magnetic fields, □ Transmission lines, ☒ Wiring/underground wiring, □ Other:		None
	Thermal	<ul> <li>☒ Boilers, ☐ Bunsen burner/hot plates, ☒ Electrical equipment, ☒ Electrical wiring, ☐ Engine exhaust,</li> <li>☐ Furnaces, ☐ Heaters, ☐ Lasers, ☐ Steam lines,</li> <li>☐ Welding surfaces, ☐ Welding torch,</li> <li>☐ other:</li> </ul>		None
	Kinetic	<ul> <li>☑ Acceleration/deceleration, ☑ Bearings, ☑ Belts,</li> <li>☑ Carts/dollies, ☐ Centrifuges, ☐ Crane loads (in motion),</li> <li>☐ Drills, ☒ Fans, ☐ Firearm Discharge,</li> <li>☐ Fork lifts, ☐ Gears, ☐ Grinders, ☒ Motors,</li> <li>☒ Power tools, ☐ Presses/shears, ☒ Saws,</li> <li>☐ Vehicles, ☐ Airplane, ☒ Vibration, ☐ Other:</li> </ul>		None
	Potential (pressure)	☐ Autoclaves, ☒ Boilers, ☒ Coiled springs, ☐ Furnaces, ☒ Gas bottles, ☐ Gas receivers, ☒ Pressure vessels, ☐ Vacuum vessels, ☒ Pressurized system (e.g., air), ☐ Steam header and lines, ☐ Stressed members, ☐ Other:		None
	Potential (height/mass)	☐ Cranes/hoists, ☐ Elevated doors, ☒ Elevated work surfaces, ☐ Elevators, ☐ Lifts, ☐ Loading docks, ☒ Mezzanines, ☐ Floor pits, ☒ Scaffolds and ladders, ☐ Stacked material, ☐ Stairs, ☐ Other:		None
	Internal Flooding Sources	<ul><li>☑ Domestic water, ☑ Fire suppression piping,</li><li>☑ Process water, ☐ Other:</li></ul>		None
Hazard Classification				
Select the appropriate hazard level from the dropdown menu:				
Biological Not found				
		LSI		
1		Not found		
		Not found Not found		
Industrial		LSI		

Controls for LSI classified facilities: (Low, Moderate and High facility controls are addressed in Tier 2 or Tier 3 SBDs.) Briefly describe controls developed to assure that facility operations do not exceed the facility classification: Use of chemicals shall be approved by facility management prior to introduction/use in the building. Signage will be placed on entrances to the building to notify personnel. Facility management controls industrial hazards within the facility through work scope and PE maintenance review. Common industrial hazards are adequately covered by OSHA regulations. Controls for hazards such as electrical and pressure are described in the LLNL ES&H Manual Volume II, Part 16 and Part 18. Other controls? Briefly describe: Entry into area will be limited to personnel placed on TESA access and to those with specific keys. List what document(s) through which the controls will be implemented: LLNL ES&H Manual. **Integration Worksheets** 

